

Chhattisgarh Electricity Regulatory Commission (Intra -state Availability Based Tariff and Deviation Settlement Mechanism) Regulations, 2016

HIGHLIGHTS

Eligible Entities	<ul style="list-style-type: none">• All renewable based power plant of installed capacity > 5MW• Deviation settlement for the regional entities will be according to the Central Electricity Regulatory Commission (Deviation Settlement Mechanism and Related Matters) Regulations, 2014, as amended from time to time.
Scheduling & Dispatch	<ul style="list-style-type: none">• Day-ahead schedule - At intervals of 15 minutes for the next day, starting from 00:00 hrs of that day.• Seller should give notice upto 9:00 hrs and buyer confirms time block upto 11.00 hrs of the day.
Tariff Under ABT	<ul style="list-style-type: none">• Fixed/capacity charges- Based on Availability of plant• Energy/ variable charges- Payable on scheduled energy• Deviation charges- Difference between Actual generation and Scheduled generation or Actual withdrawal and Scheduled withdrawal

OTHER PROVISIONS

Deviation charges for sale of power within the state	Under injection (for plants commissioned before the date of notification).	
	Absolute Error in a15-min time block	Deviation Charges payable to State DSM Pool
	≤15%	At the Fixed Rate for the shortfall energy upto for absolute error upto 15%
	>15% but ≤ 25%	At the Fixed Rate for the shortfall energy for absolute error upto 15%+110% of the Fixed Rate for balance energy beyond 15% & upto 25%
	>25% but ≤35%	At the Fixed Rate for the shortfall energy for absolute error upto 15%+110% of the Fixed Rate for balance energy beyond 15% & upto 25%+120% of the Fixed Rate for balance energy beyond 25% & upto 35%
	>35%	At the Fixed Rate for the shortfall energy for absolute error upto 15%+110% of the Fixed Rate for balance energy beyond 15% & upto 25%+120% of the Fixed Rate for balance energy beyond25% & upto 35%+130% of thr Fixed Rate for balanced energy beyond 35%
Deviation charges for sale of power within the state	Over injection (for plants commissioned before the date of notification).	
	Absolute Error in a15-min time block	Deviation Charges payable to State DSM Pool
	≤15%	At the Fixed Rate for the shortfall energy upto for absolute error upto 15%
	>15% but ≤ 25%	At the Fixed Rate for the shortfall energy for absolute error upto 15%+90% of the Fixed Rate for balance energy beyond 15% & upto 25%
	>25% but ≤35%	At the Fixed Rate for the shortfall energy for absolute error upto 15%+90% of the Fixed Rate for balance energy beyond 15% & upto 25%+80% of the Fixed Rate for balance energy beyond 25% & upto 35%
>35%	At the Fixed Rate for the shortfall energy for absolute error upto 15%+90% of the Fixed Rate for balance energy beyond 15% & upto 25%+80% of the Fixed Rate for balance energy beyond25% & upto 35%+70% of thr Fixed Rate for balanced energy beyond 35%	
Link	http://cserc.gov.in/regulation.htm	
Reference	http://cserc.gov.in/pdf/Regulations_Notified/74-CSERC%20(Intra-state%20Availability%20Based%20Tariff%20and%20Deviation%20Settlement%20Mechanism)%20Regulations,%202016.pdf	