## Rajasthan Net Metering Regulations â€" 2015 (Consolidated 1st Amendment)

## **HIGHLIGHTS**

Eligibility Conditions	<ul> <li>Consumer should be in the supply area of the distribution licensee.</li> <li>Plant capacity should not be more than 80% of sanctioned connected load.</li> <li>Minimum plant capacity should be more than 1 kWp and maximum 1 MWp.</li> </ul>
Capacity Target for Distribution Licensee	Cumulative capacity should be restricted to 30% of the rated capacity of the respective distribution transformer.
Metering Arrangement	<ul> <li>Bi-directional meter will be installed at the interconnection point with the network of the distribution licensee.</li> <li>Existing meters of consumers would be replaced by net meters.</li> <li>Check meters are mandatory for systems having capacity of more than 250 kW but optional otherwise.</li> </ul>

## **OTHER PROVISIONS**

Energy Accounting and Settlement	<ul> <li>Domestic category consumers where electricity injected exceeds electricity consumed: <ul> <li>Electricity injected up to 100 units will be adjusted in the next billing period.</li> <li>Excess electricity injected above 100 units will be paid @ Rs.3.14/unit.</li> <li>Capping of the average generation of 4.8 units per kW of the approved installed capacity per day of the rooftop solar PV system will be applicable.</li> <li>For non-domestic consumers a cap of 4.8 units per kW/day of approved installed capacity is applicable.</li> </ul> </li> <li>Excess energy injected will not be compensated.</li> <li>If a consumer leaves the system, the excess energy credit shall lapse and no reimbursement will be given.</li> </ul>
Other Charges	Exemption from banking and wheeling charges and cross-subsidy surcharge.
Penalty	As decided by the Commission from time to time.
Links	http://rerc.rajasthan.gov.in/
Reference	http://rerc.rajasthan.gov.in/Regulations/Order84.pdf http://rerc.rajasthan.gov.in/Regulations/Reg113.pdf