Rajasthan Net Metering Regulations â€“ 2015 (Consolidated 1st Amendment)

HIGHLIGHTS

Eligibility Conditions	• Consumer should be in the supply area of the distribution licensee. • Plant capacity should not be more than 80% of sanctioned connected load. • Minimum plant capacity should be more than 1 kWp and maximum 1 MWp.
Capacity Target for Distribution Licensee	Cumulative capacity should be restricted to 30% of the rated capacity of the respective distribution transformer.
Metering Arrangement	• Bi-directional meter will be installed at the interconnection point with the network of the distribution licensee. • Existing meters of consumers would be replaced by net meters. • Check meters are mandatory for systems having capacity of more than 250 kW but optional otherwise.

OTHER PROVISIONS

Energy Accounting and Settlement	• Domestic category consumers where electricity injected exceeds electricity consumed: - Electricity injected up to 100 units will be adjusted in the next billing period. - Excess electricity injected above 100 units will be paid @ Rs.3.14/unit. - Capping of the average generation of 4.8 units per kW of the approved installed capacity per day of the rooftop solar PV system will be applicable. - For non-domestic consumers a cap of 4.8 units per kW/day of approved installed capacity is applicable. Excess energy injected will not be compensated. - If a consumer leaves the system, the excess energy credit shall lapse and no reimbursement will be given.
Other Charges	Exemption from banking and wheeling charges and cross-subsidy surcharge.
Penalty	As decided by the Commission from time to time.
Links	http://rerc.rajasthan.gov.in/
Reference	http://rerc.rajasthan.gov.in/Regulations/Order84.pdf http://rerc.rajasthan.gov.in/Regulations/Reg113.pdf